

JAIPUR ZILA DUGDH UTPADAK SAHAKARI SANGH LIMITED

Near Gandhi Nagar Railway Station, Jaipur - 302015

EPABX No. : 91-0141-2713666-69, Fax No. : 0141-2711075, Email :

jaipurdairypurchase@gmail.com www.jaipurdairy.com

No. JZDUSSL/UPS/25-26/

Date:- 07/05/2025

3877-79

Tender Amendment

E-Tender of Dismantling of existing UPS and Supply, Installation, Testing & commissioning of three nos. 160 KVA online UPS at Jaipur Dairy UHT Plant invited on 30.04.2025. Following technical amendments are made in tender documents: -

Technical Amendment:

All bidders must consider the following amendments in the tender document before submitting the bid and this amendment will be part & parcel of initial tender document hence all bidders should seal & signed this amendment and upload with bid. (Other than this amendment rest terms & condition, specification of the original initial tender document will be same without any change)

Annexure-II (Amendments)

Technical Specifications:

(A) TECHNICAL SPECIFICATIONS AND DATA SHEET FOR SUPPLY, INSTALLATION, TESTING & COMMOSSIONING OF 160 KVA ONLINE UPS

Input Power factor > 0.99 and Input THDi < 3% without using any filter (Only IGBT technology-based UPS should be offered, SCR based UPS will be technically rejected).

(B) TECHNICAL SPECIFICATIONS AND DATA SHEET FOR SUPPLY, INSTALLATION, TESTING & COMMOSSIONING OF 160 KVA ONLINE UPS

Approved Make for UPS: - "Riello or equivalent" make also added with the existing approves ups makes

- 1) Input Power factor > 0.99 and Input THDi < 3% without using any filter (Only IGBT technology based UPS should be offered, SCR based UPS will be technically rejected)
- 2) Inbuilt Maintenance Bypass----- Required
- 3) Built-in Output transformer-based UPS to be offered.

Annexure-III: (Amendment in BOQ)


BOQ:

Sr. No.	Item Description	Amendment
3.0	Battery charger	Battery charger must be inbuilt with online UPS
4.0	Battery Junction box	Bidder must quote three nos 400amp battery circuit breaker for each battery bank instead of battery junction box
5.0	DC links for Batteries	DC links must be considered for 120 nos batteries instead 96 batteries

Note: (Amendment)

1. Instead of 96 nos batteries 120 nos. of 200Ah batteries (12 volt) will be provided by the JZDUSS but installation, testing & commissioning of batteries will be in the scope of supplier.

This bears the approval of competent authority.


Incharge (Tender Cell)

Copy to: -

1. Incharge (Engg/Tender/APS/F &A)


Incharge (Tender Cell)



Financial Year: 2025-2026 NIB Document

[English n हिन्दी] 106.99 KB

Department : Rajasthan Co-operative Dairy Federation Limited

NIB Ref No. : JZDUSSL/ENGG/2025-26/3048

NIB Code : CDF2526A0123

NIB Publish Date : 30/04/2025

Uploaded Bid Documents : 1 / 1

DATE

CORRIGENDUM

1.	Last date &time of sale of tender documents and bids can be submitted	12.05.2025 up to 01:00 pm
2.	Last date &time up to which tender form and EMD fee,MD,RISL can be submitted	12.05.2025 up to 03:00 pm
3.	Date and time of opening of Technical bid	13.05.2025 up to 01:00 pm